

MODULAR ENCLOSURE FOR FIRE ALARM

IMRR21 & IMRR71



MANUAL ACTUATION



AUTOMATIC ACTUATION

MODULAR ENCLOSURE TO FIRE ALARM

Technical data

SPECIFICATIONS

TYPE OF PROTECTION	Ex "d" – Flameproof Ex "e" - Increased Safety Ex "t" – Dust Ignition Protection
MARKING	Ex db eb IIC T6 Gb IP66W Ex tb IIIC T 85 ° C Db
AREA OF APPLICATION	Zone 1 Zone 2 Zone 21 Zone 22
INGRESS PROTECTION	IP66W (W: Salt Spray)
TEMPERATURE CLASS	T6: I=10A (max)
CERTIFICATE OF CONFORMITY	

Segurança



OCP 0034



INMETRO

INMETRO

NCC 24.0123

DIMENSIONS(MM)

IMRR21 & IMRR71



MODULAR ENCLOSURE TO FIRE ALARM



Technical data

FEATURES

MUSHROOM HEAD THAT CAN BE USED



CONTACT BLOCKS THAT CAN BE USED



NOTE:

MANUAL ACTUATION: THE GLASS MUST BE BROKEN AND THE BUTTON MUST BE PUSHED MANUALLY. GBETR AND GBEMO CAN BE USED.
AUTIMATIC ACTUATION: WHEN THE GLASS IS BROKEN THE BUTTON IS AUTOMATIC ACTUATED .GBEMO MUST BE USED.

OPTIONAL THREADED HOLES

**OPTIONAL THREADED HOLES FOR CABLE INLETS / OUTLETS
(MAXIMUM ONE HOLE PER FACE)**

THREADS	FACE A	FACE B	FACE C
BSP			
1"	X	X	X
3/4"	X	X	X
1/2"	X	X	X
METRIC			
M20x1,5	X	X	X
M22x1,5	X	X	X
M25x1,5	X	X	X
M32x1,5	X	X	X

FACE C

FACE B

FACE A